


NOTIFICATION APPLIANCE CIRCUIT POWER REQUIREMENTS — 2ND FLOOR FROM SIEMENS DRAWING FA-03 700 0.852 3.134 20.866 0.952 3.509 700 0.822 3.024 20.976 0.947 3.490 20.510

THE FOLLOWING SIEMENS HORNS AND ASSOCIATED LOADS WERE USED FOR THESE CALCULATIONS.


OTHER HORNS MAY BE USED PROVIDED THEIR CURRENT DRAW DOES NOT EXCEED THOSE SHOWN FOR

1. SIEMENS SERIES AH, WALL MOUNTED HORN; 0.025 AMP MAX UL POWER DEMAND (MIDDLES SETTING FOR 84 DBA); RATED 16 TO 33 AMP



RACEWAY NOTES:

1. UNLESS NOTED OTHERWISE, THE RACEWAYS SHOWN ON THIS SHEET CONTAIN CIRCUITS L3, AV7, AV8 & AV9.



WRNSSTUDIO

501 SECOND STREET 4TH FLOOR, STE. 402 SAN FRANCISCO **CALIFORNIA 94107** 415.489.2224 TEL 415.358.9100 FAX WWW.WRNSSTUDIO.COM

> Missing or invalid reference File: .\Tresidder 2012 PE Stamp Sheet: 1




HYT Corporation Fire Protection Engineers and Consultants

3498 Clayton Road - Suite 101

Concord, California 94519 Phone: (925) 681-2731 FAX: (925) 681-2733 ISSUES/REVISONS

FINAL AS-BUILTS RECORD DRAWINGS 02-18-11

LBNL ADVANCED LIGHT SOURCE USER SUPPORT BUILDING 15 BERKELEY, CA



THIRD FLOOR PLAN FIRE ALARM

5N15E044

SHEET NO: FN1421